RFR - RF Room Thermostat

Operating Instructions

Contents

- Factory default settings
- Specification & wiring
- Mounting
- Installation
- Button / symbol description
- Resetting the thermostat
- **Boost function**
- Lock function
- To connect the RFR thermostat to the R_7-RF programmer
- 10. To disconnect the RFR thermostat from the R_7-RF programmer

Important: Keep this document

Prior to setting the thermostat, it is neccessary to complete all required settings described in this section.





CAUTION!

Only qualified electricians or authorised service staff are permitted to open the thermostat.

Ensure that this wireless enabled thermostat is installed 1 metre from any metalic object, television, radio or wireless internet transmitter.

1. Factory default settings



Temperature indicator: Switching differential: 0.2°C In built frost protection: 5°C Keypad lock: Off

2. Specifications & wiring

Power Supply: 2 x AAA Alkaline Battery

The mounting height should be 1.5 meters above the floor level. The

thermostat should be wall mounted in the room where the heating is to

The place of installation should be chosen so that the sensor can measure

Choose the mounting location to prevent direct exposure to sunlight or

1. Recessed conduit boxes

2. Surface mounting boxes 3. Directly on walls


4. Table mounting with stand provided

Power consumption: 50 uA **Battery replacement:** Once per year Temp. Control Range: 5...35°C 84 * 84 * 30mm **Dimensions:** NTC 10K Ohm @ 25°C Temp. sensor:

Temp. indication:

Heating ON symbol

5. Button / symbol description



6. Resetting the thermostat

Press the O button on the bottom of the thermostat, the front housing will detach from the baseplate.

Code button

Insert the batteries into the thermostat.

Press the reset button on the PCB, 'NO' will flash on the screen.

Reset button

Rotate the hand wheel clockwise until 'YES' appears on the screen.

Press the hand wheel once to confirm the setting.

The thermostat has now been reset and the current temperature will appear on the screen.

7. Boost function

Press the boost button once, twice or three times to boost the heating for 1, 2 or 3 hours respectively. +1H, +2H or +3H will appear on the screen. The boost function will override the programmer if the programmer is timed to be Off.

4. Installation

The unit can be fitted to:

3. Mounting

Press the button on the bottom of the thermostat.

the room temperature as accurately as possible.

other heating / cooling sources when mounted.

The front housing will detach from the baseplate.

Insert the batteries (provided) into the thermostat.

Mount the unit as described in section 3.

Offer the baseplate up to the thermostat. Snap it into position to close.

8. Lock function

To lock the thermostat, press the hand wheel for 10 seconds. The keypad symbol will appear on the screen.

To unlock the thermostat, press the hand wheel for 10 seconds. The keypad symbol will disappear from the screen.



RFR - RF Room Thermostat

Operating Instructions

9. To connect the RF thermostat with the programmer

On the timeswitch / programmer

Lower the front cover and move the selector switch to the **RUN** position.

CLOCK RUN PROG

Press the — button for 5 seconds.

Wireless Connect will appear on the screen.

On the RFR wireless room thermostat or RFC wireless cylinder thermostat

Press the Code button. This is located inside the housing on the Printed Circuit Board.

On the timeswitch / programmer

The available zones will begin to flash.

Press the $\fbox{\mbox{\tt ZONE SELECT}}$ button for the zone you wish to connect the thermostat to.

The wireless symbol Ψ appears on the screen.

The thermostat will count upwards to the number of the zone that it is paired with. When it reaches the number of the zone that it is paired with press the hand wheel on the thermostat.

The timeswitch / programmer is now operating in the wireless mode. The temperature of the wireless thermostat is now displayed on the programmer. Repeat this process for the second, third and fourth zone if required.

10. To disconnect the RF thermostat with the programmer

On the timeswitch / programmer

Lower the front cover and move the selector switch to the **RUN** position.

CLOCK RUN PRO

Press the button for 5 seconds.

This will take you into the Wireless Connect screen.

Press the _ button for 3 seconds.

This will clear all RF connections thereby disconnecting all thermostats from

the timeswitch / programmer.

Press the OK button.



EPH Controls Ireland

sales@ephcontrols.com www.ephcontrols.com